



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)  
BOARD AND CODE ADMINISTRATION DIVISION

## NOTICE OF ACCEPTANCE (NOA)

MIAMI-DADE COUNTY  
PRODUCT CONTROL SECTION  
11805 SW 26 Street, Room 208  
T (786) 315-2590 F (786) 315-2599  
[www.miamidade.gov/economy](http://www.miamidade.gov/economy)

Kolbe & Kolbe Millwork Co., Inc.  
1211 Depot Street  
Manawa, WI 54949

### SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code, including the High Velocity Hurricane Zone.

**DESCRIPTION:** Series "V707 Windquest" White PVC Horizontal Sliding Window - L.M.I.

**APPROVAL DOCUMENT:** Drawing No. 08-01323, titled "Windquest V707 Single Slider - 74" x 63", sheets 1 through 9 of 9, dated 08/02/11, with revision B dated 10/11/13, prepared by manufacturer, signed and sealed by Luis R. Lomas, P.E., bearing the Miami-Dade County Product Control Revision stamp with the Notice of Acceptance number and expiration date by the Miami-Dade County Product Control Section.

**MISSILE IMPACT RATING:** Large and Small Missile Impact Resistant

**LABELING:** Each unit shall bear a permanent label with the manufacturer's name or logo, city, state, model/series, and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

**RENEWAL** of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

**TERMINATION** of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

**ADVERTISEMENT:** The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

**INSPECTION:** A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA revises and renews NOA# 11-1018.07 and consists of this page 1 and evidence pages E-1 and E-2, as well as approval document mentioned above.

The submitted documentation was reviewed by Manuel Perez, P.E.



*MP*  
*10/17/13*

NOA No. 13-0805.04  
Expiration Date: October 30, 2018  
Approval Date: October 24, 2013  
Page 1

**NOTICE OF ACCEPTANCE: EVIDENCE SUBMITTED**

**A. DRAWINGS**

1. Manufacturer's die drawings and sections.
2. Drawing No **08-01323**, sheets 1 through 9 of 9, titled "Windquest V707 Single Slider - 74" x 63", dated 08/02/11, with revision B dated 10/11/13, prepared by manufacturer, signed and sealed by Luis R. Lomas, P.E.

**B. TESTS**

1. Test reports on: 1) Air Infiltration Test, per FBC, TAS 202-94  
2) Uniform Static Air Pressure Test, Loading per FBC TAS 202-94  
3) Water Resistance Test, per FBC, TAS 202-94  
4) Large Missile Impact Test per FBC, TAS 201-94  
5) Cyclic Wind Pressure Loading per FBC, TAS 203-94  
6) Forced Entry Test, per FBC 2411 3.2.1, TAS 202-94

along with marked-up drawings and installation diagram of series Windquest V707 horizontal sliders XO with three different mounting conditions, prepared by National Certified Testing Laboratories, Test Report No. **NCTL-110-13977-1**, dated 06/15/10, revised on 05/27/11, signed and sealed by Robert H. Zeiders, P.E.

*(Submitted under previous NOA #11-1018.07)*

2. Test reports on: 1) Air Infiltration Test, per FBC, TAS 202-94  
2) Uniform Static Air Pressure Test, Loading per FBC TAS 202-94  
3) Water Resistance Test, per FBC, TAS 202-94  
4) Large Missile Impact Test per FBC, TAS 201-94  
5) Cyclic Wind Pressure Loading per FBC, TAS 203-94  
6) Forced Entry Test, per FBC 2411 3.2.1, TAS 202-94

along with marked-up drawings and installation diagram of a series V707HS white PVC horizontal sliding window, prepared by National Certified Testing Laboratories, Test Report No. **NCTL-110-10633-9**, dated 09/13/06, signed and sealed by Harold E. Rupp, P.E.

*(Submitted under NOA# 08-0324.14)*

**C. CALCULATIONS:**

1. Anchor verification calculations and structural analysis, complying with FBC-2007 and 2010, dated 11/26/07, revised on 08/02/11 and 01/27/12, prepared, signed and sealed by Luis R. Lomas, P.E.

*(Submitted under previous NOA #11-1018.07)*

2. Glazing complies with ASTM E1300-04



Manuel Perez, P.E.  
Product Control Examiner  
NOA No. 13-0805.04

Expiration Date: October 30, 2018

Approval Date: October 24, 2013

**NOTICE OF ACCEPTANCE: EVIDENCE SUBMITTED**

**D. QUALITY ASSURANCE**

1. Miami-Dade Department of Regulatory and Economic Resources (RER)

**E. MATERIAL CERTIFICATIONS**

1. Notice of Acceptance No. **13-0129.27** issued to **E.I. DuPont DeNemours & Co., Inc.** for their "**DuPont Butacite® PVB Interlayer**" dated 04/11/13, expiring on 12/11/16.
2. Notice of Acceptance No. **12-0620.09** issued to Royal Window and Door Profiles for their "**White Rigid PVC Exterior Profile Extrusions for Windows and Doors**" dated 09/13/12, expiring on 07/05/17.

**F. STATEMENTS**

1. Statement letter of conformance, complying with **FBC-2010**, and of no financial interest, dated 05/21/13, signed and sealed by Luis R. Lomas, P.E.

**G. OTHERS**

1. Notice of Acceptance No. **11-1018.07**, issued to Kolbe & Kolbe Millwork Co., Inc. for their Series "**V707 Windquest**" White PVC Horizontal Sliding Window – L.M.I., approved on 01/23/12 and expiring on 10/30/13.


  
Manuel Perez, P.E.

Product Control Examiner

NOA No. 13-0805.04

Expiration Date: October 30, 2018

Approval Date: October 24, 2013



**WINDQUEST V707 SINGLE SLIDER**  
EXTERIOR VIEW FRAME FLUSH INSTALLATION

DESIGN PRESSURE RATING	IMPACT RATING
±50PSF	LARGE AND SMALL MISSILE IMPACT

MISSILE LEVEL D, WIND ZONE 4, AND HVHZ

REVISIONS			
REV	DESCRIPTION	DATE	APPROVED
A	ADDED ANCHOR CLUSTERS	1/27/12	R.L.
B	REVISED B.O.M.	10/11/13	R.L.

**NOTES:**

- 1) THE PRODUCT SHOWN HEREIN IS DESIGNED AND MANUFACTURED TO COMPLY WITH REQUIREMENTS OF THE FLORIDA BUILDING CODE INCLUDING THE HVHZ.
- 2) WOOD FRAMING AND MASONRY OPENING TO BE DESIGNED AND ANCHORED TO PROPERLY TRANSFER ALL LOADS TO STRUCTURE. FRAMING AND MASONRY OPENING IS THE RESPONSIBILITY OF THE ARCHITECT OR ENGINEER OF RECORD.
- 3) 1X BUCK OVER MASONRY/CONCRETE IS OPTIONAL. WHERE 1X BUCK IS NOT USED DISSIMILAR MATERIALS MUST BE SEPARATED WITH APPROVED COATING OR MEMBRANE. SELECTION OF COATING OR MEMBRANE IS THE RESPONSIBILITY OF THE ARCHITECT OR ENGINEER OF RECORD.
- 4) ALLOWABLE STRESS INCREASE OF 1/3 WAS NOT USED IN THE DESIGN OF THE PRODUCT SHOWN HEREIN. WIND LOAD DURATION FACTOR  $C_d=1.6$  WAS USED FOR WOOD ANCHOR CALCULATIONS.
- 5) FRAME MATERIAL: EXTRUDED RIGID PVC.
- 6) UNITS MUST BE GLAZED PER ASTM E1300, SEE SHEET 3 FOR GLASS OPTIONS.
- 7) APPROVED IMPACT PROTECTIVE SYSTEM IS NOT REQUIRED FOR THIS PRODUCT IN WIND BORNE DEBRIS REGIONS.
- 8) SHIM AS REQUIRED AT EACH INSTALLATION ANCHOR WITH LOAD BEARING SHIM. SHIM WHERE SPACE OF 1/16" OR GREATER OCCURS. MAXIMUM ALLOWABLE SHIM STACK TO BE 1/4".
- 9) FOR ANCHORING INTO MASONRY/CONCRETE USE 3/16" TAPCONS WITH SUFFICIENT LENGTH TO ACHIEVE A 1 1/4" MINIMUM EMBEDMENT INTO SUBSTRATE WITH 2 1/2" MINIMUM EDGE DISTANCE. LOCATE ANCHORS AS SHOWN IN ELEVATIONS AND INSTALLATION DETAILS.
- 10) FOR ANCHORING INTO WOOD FRAMING OR 2X BUCK USE #8 WOOD SCREWS WITH SUFFICIENT LENGTH TO ACHIEVE A 1 1/4" MINIMUM EMBEDMENT INTO SUBSTRATE. LOCATE ANCHORS AS SHOWN IN ELEVATIONS AND INSTALLATION DETAILS.
- 11) FOR ANCHORING INTO METAL STRUCTURE USE #8 SMS OR SELF DRILLING SCREWS SCREWS WITH SUFFICIENT LENGTH TO ACHIEVE 3 THREADS MINIMUM BEYOND STRUCTURE INTERIOR WALL. LOCATE ANCHORS AS SHOWN IN ELEVATIONS AND INSTALLATION DETAILS.
- 12) ALL FASTENERS TO BE CORROSION RESISTANT.
- 13) INSTALLATION ANCHORS SHALL BE INSTALLED IN ACCORDANCE WITH ANCHOR MANUFACTURER'S INSTALLATION INSTRUCTIONS, AND ANCHORS SHALL NOT BE USED IN SUBSTRATES WITH STRENGTHS LESS THAN THE MINIMUM STRENGTH SPECIFIED BELOW:
  - A. WOOD - MINIMUM SPECIFIC GRAVITY OF  $G=0.42$
  - B. CONCRETE - MINIMUM COMPRESSIVE STRENGTH OF 3,192 PSI.
  - C. MASONRY - STRENGTH CONFORMANCE TO ASTM C-90, GRADE N, TYPE 1 (OR GREATER).
  - D. METAL STRUCTURE: STEEL 18GA, 33KSI OR ALUMINUM 6063-T5 1/8" THICK MINIMUM
- 14) APPROVED CONFIGURATIONS: OX,XO.

TABLE OF CONTENTS	
SHEET NO.	DESCRIPTION
1, 2	ELEVATION, ANCHORING AND NOTES
3	CROSS SECTIONS AND B.O.M.
4 - 8	INSTALLATION DETAILS
9	COMPONENTS

PRODUCT REVISED  
as complying with the Florida  
Building Code  
Acceptance No. 13-0805.04  
Expiration Date 01-30-2018  
By *Manuel Perez*  
Miami Dade Product Control


**KOLBE & KOLBE MILLWORK**

1211 DEPOT ST  
MANAWA, MI 54949

WINDQUEST V707 SINGLE SLIDER  
74 X 63  
ELEVATION AND NOTES


DRAWN: R.L.	DWG NO. 08-01323	REV B
SCALE NTS	DATE 08/02/11	SHEET 1 OF 9

SIGNED: 10/11/2013



REVISIONS



REV	DESCRIPTION	DATE	APPROVED
A	ADDED ANCHOR CLUSTERS	1/27/12	R.L.
B	REVISED B.O.M.	10/11/13	R.L.



**WINDQUEST V707 SINGLE SLIDER**  
EXTERIOR VIEW STRAP INSTALLATION

DESIGN PRESSURE RATING	IMPACT RATING
±50PSF	LARGE AND SMALL MISSILE IMPACT

MISSILE LEVEL D, WIND ZONE 4, AND HVHZ



**WINDQUEST V707 SINGLE SLIDER**  
EXTERIOR VIEW NAILING FIN INSTALLATION

DESIGN PRESSURE RATING	IMPACT RATING
±50PSF	LARGE AND SMALL MISSILE IMPACT

MISSILE LEVEL D, WIND ZONE 4, AND HVHZ

PRODUCT REVISED  
as complying with the Florida  
Building Code  
Acceptance No. 13-0805.04  
Expiration Date 02/23/2018  
By *Mamuel Perez*  
Miami/Dade Product Control


**KOLBE & KOLBE MILLWORK**

1211 DEPOT ST  
MANAWA, MI 54949


WINDQUEST V707 SINGLE SLIDER  
74 X 63  
ELEVATION AND NOTES

DRAWN: R.L.	DWG NO. 08-01323	REV B
SCALE NTS	DATE 08/02/11	SHEET 2 OF 9

SIGNED: 10/11/2013



PARTS LIST				
NO.	PART NUMBER	DESCRIPTION	MANUFACTURER	MATERIAL
1	4254	MULLION	ROYAL	WHITE PVC
2	4202	FRAME	ROYAL	WHITE PVC
3	4008	SILL COVER	ROYAL	WHITE PVC
4	4084A	SASH INTERLOCK	ROYAL	WHITE PVC
5	4027A	SASH FRAME	ROYAL	WHITE PVC
6	4299	JAMB ADAPTER	ROYAL	WHITE PVC
7	4219	SILL ADAPTER	ROYAL	WHITE PVC
8	4022	7/8" GLAZING BEAD	ROYAL	WHITE PVC
9	4010	SASH STOP	ROYAL	WHITE PVC
10	4013	7/8" GLAZING BEAD	ROYAL	WHITE PVC
11		7/16" SCREEN FRAME		
12	HF-7320-187	WHEATHERSTRIP	SCHLEGEL	
13	PB-8830-187	WHEATHERSTRIP	SCHLEGEL	
14	DPAB	WHEATHERSTRIP 1.062-200FIN	SCHLEGEL	
15		SETTING BLOCK 7/8" X 1 X 1/8"		80 DUROMETER
16	808-0018	TILT LATCH	ROYAL	
17	4076	ROLLERS	ROYAL	
18	995	STRUCTURAL SEALANT	DOW CORNING	
19	SL047500	LOCK	ROTO	
20	SL047550	KEEPER	ROTO	
21		SCREEN SPRING		
22		GLAZING TAPE .5" X 1/6"		
23	4052	MULLION CONNECTOR		
24	4053	SCREEN SUPPORT		
25		LOCK SCREWS FH #6 X 1"		
26		KEEPER SCREWS FH #6 X 1 1/2"		
27	2222	MULLION CONNECTOR SCREWS		
28		SCREEN SUPPORT FH #8 X 1/2"		
29	97-03-00-00	VALVE	GEARMOLD	
30	A112-02M096	MULLION REINFORCEMENT		ALUMINUM 6063-T5
31		RECEPTACLE SCREWS FH #10 X 2"		
32		TILT LATCH SCREWS FH #8 X 1"		
33	A110-02M096	SASH REINFORCEMENT		ALUMINUM 6063-T5
34		REINFORCEMENT SCREWS FH #10X2"		
35		MULLION SCREWS PH #10 X 3"		
36	A111-02M096	MEETING RAIL REINFORCEMENT		ALUMINUM 6063-T5
37	4560	INSTALLATION STRIP		STEEL G60
38	4202E	FRAME, NAILING FIN	ROYAL	WHITE PVC



REVISIONS			
REV	DESCRIPTION	DATE	APPROVED
A	ADDED ANCHOR CLUSTERS	1/27/12	R.L.
B	REVISED B.O.M.	10/11/13	R.L.

SIGNED: 10/11/2013


PRODUCT REVISED  
as complying with the Florida  
Building Code  
Acceptance No. 13-0805.04  
Expiration Date 02/30/2018  
By *Manuel Perez*  
Miami Dade Product Control



KOLBE & KOLBE MILLWORK

1211 DEPOT ST  
MANAWA, MI 54949

WINDQUEST V707 SINGLE SLIDER  
74 X 63  
CROSS SECTIONS AND B.O.M.



DRAWN: R.L.	DWG NO. 08-01323	REV B
SCALE NTS	DATE 08/02/11	SHEET 3 OF 9






**SECTION A**  
FLUSH INSTALLATION  
WOOD FRAMING OR 2X BUCK

NOTE:  
INTERIOR AND EXTERIOR FINISHES, BY OTHERS, NOT SHOWN FOR CLARITY.




**SECTION A**  
FLUSH INSTALLATION  
METAL STRUCTURE

REVISIONS			
REV	DESCRIPTION	DATE	APPROVED
A	ADDED ANCHOR CLUSTERS	1/27/12	R.L.
B	REVISED B.O.M.	10/11/13	R.L.



**SECTION B**  
FLUSH INSTALLATION  
METAL STRUCTURE



**SECTION B**  
FLUSH INSTALLATION  
WOOD FRAMING OR 2X BUCK

SIGNED: 10/11/2013


PRODUCT REVISED  
as complying with the Florida  
Building Code  
Acceptance No. 13-0805.04  
Expiration Date 02.30.2018  
By *Maurice J. [Signature]*  
Miami Dade Product Control



KOLBE & KOLBE MILLWORK

1211 DEPOT ST  
MANAWA, MI 54949

WINDQUEST V707 SINGLE SLIDER  
74 X 63  
INSTALLATION DETAILS


DRAWN: R.L.	DWG NO. 08-01323	REV B
SCALE NTS	DATE 08/02/11	SHEET 4 OF 9





**SECTION**  
**A**  
**5** FLUSH INSTALLATION  
CONCRETE/MASONRY

REVISIONS			
REV	DESCRIPTION	DATE	APPROVED
A	ADDED ANCHOR CLUSTERS	1/27/12	R.L.
B	REVISED B.O.M.	10/11/13	R.L.



**SECTION**  
**B**  
**5** FLUSH INSTALLATION  
CONCRETE/MASONRY


NOTE:  
INTERIOR AND EXTERIOR FINISHES, BY OTHERS, NOT SHOWN FOR CLARITY.

SIGNED: 10/11/2013

PRODUCT REVISED  
as complying with the Florida  
Building Code  
Acceptance No 13-0805-04  
Expiration Date 02/30/2018  
By *Manuel Cruz*  
Miami Dade Product Control



KOLBE & KOLBE MILLWORK  
1211 DEPOT ST  
MANAWA, MI 54949  
WINDQUEST V707 SINGLE SLIDER  
74 X 63  
INSTALLATION DETAILS

DRAWN: R.L.	DWG NO. 08-01323	REV B
SCALE NTS	DATE 08/02/11	SHEET 5 OF 9





REVISIONS			
REV	DESCRIPTION	DATE	APPROVED
A	ADDED ANCHOR CLUSTERS	1/27/12	R.L.
B	REVISED B.O.M.	10/11/13	R.L.



NOTE:  
 INTERIOR AND EXTERIOR FINISHES, BY OTHERS, NOT SHOWN FOR CLARITY.

PRODUCT REVISED  
 as complying with the Florida  
 Building Code  
 Acceptance No. 13-0805.04  
 Expiration Date 02.30.2018

By *[Signature]*  
 Miami Dade Product Control


**KOLBE & KOLBE MILLWORK**  
 1211 DEPOT ST  
 MANAWA, MI 54949

WINDQUEST V707 SINGLE SLIDER  
 74 X 63  
 INSTALLATION DETAILS

DRAWN: R.L.  
 SCALE: NTS  
 DATE: 08/02/11  
 SHEET: 6 OF 9


DWG NO.: 08-01323  
 REV: B

LUIS R. LOMAS  
 LICENSED PROFESSIONAL ENGINEER  
 No. 82514  
 STATE OF FLORIDA



EXTERIOR


INTERIOR



C  
7

SECTION  
STRAP INSTALLATION  
CONCRETE/MASONRY

REVISIONS			
REV	DESCRIPTION	DATE	APPROVED
A	ADDED ANCHOR CLUSTERS	1/27/12	R.L.
B	REVISED B.O.M.	10/11/13	R.L.



INTERIOR

EXTERIOR

D  
7

SECTION  
STRAP INSTALLATION  
CONCRETE/MASONRY

NOTE:  
INTERIOR AND EXTERIOR FINISHES, BY OTHERS, NOT SHOWN FOR CLARITY.

SIGNED: 10/11/2013


PRODUCT REVISED  
as complying with the Florida  
Building Code  
Acceptance No. 13-0805-04  
Expiration Date 05-30-2018  
By *Manuel Perez*  
Miami Dade Product Control

KOLBE & KOLBE MILLWORK


1211 DEPOT ST  
MANAWA, MI 54949

WINDQUEST V707 SINGLE SLIDER  
74 X 63  
INSTALLATION DETAILS


DRAWN: R.L.	DWG NO. 08-01323	REV B
SCALE NTS	DATE 08/02/11	SHEET 7 OF 9




REVISIONS			
REV	DESCRIPTION	DATE	APPROVED
A	ADDED ANCHOR CLUSTERS	1/27/12	R.L.
B	REVISED B.O.M.	10/11/13	R.L.



**E**  
8 SECTION  
STRAP INSTALLATION  
WOOD FRAMING OR 2X BUCK



**F**  
8 SECTION  
STRAP INSTALLATION  
WOOD FRAMING OR 2X BUCK



**F**  
8 SECTION  
STRAP INSTALLATION  
WOOD FRAMING OR 2X BUCK

NOTE:  
INTERIOR AND EXTERIOR FINISHES, BY OTHERS, NOT SHOWN FOR CLARITY.


PRODUCT REVISED  
as complying with the Florida  
Building Code  
Acceptance No. 13-0805-04  
Expiration Date 02/30/2018  
By *Maurice Perez*  
Miami Dade Product Control

**KOLBE & KOLBE MILLWORK**  
1211 DEPOT ST  
MANAWA, MI 54949


**WINDQUEST V707 SINGLE SLIDER**  
74 X 63  
**INSTALLATION DETAILS**

DRAWN: R.L.	DWG NO. 08-01323	REV B
SCALE NTS	DATE 08/02/11	SHEET 8 OF 9


SIGNED: 10/11/2013




REVISIONS			
REV	DESCRIPTION	DATE	APPROVED
A	ADDED ANCHOR CLUSTERS	1/27/12	R.L.
B	REVISED B.O.M.	10/11/13	R.L.




① **MULLION**  
VINYL PVC .059 THICK




② **FRAME**  
VINYL PVC .069 THICK




③ **SILL COVER**  
VINYL PVC .051 THICK




④ **SASH INTERLOCK**  
VINYL PVC .069 THICK




⑤ **SASH FRAME**  
VINYL PVC .069 THICK




⑦ **JAMB ADAPTER**  
VINYL PVC .063 THICK




⑧ **SILL ADAPTER**  
VINYL PVC .069 THICK




⑧ **7/8\" GLAZING BEAD**  
VINYL PVC .059 THICK




⑨ **SASH STOP**  
VINYL PVC .047 THICK




⑩ **7/8\" GLAZING BEAD**  
VINYL PVC .059 THICK




③⑦ **MULLION REINFORCEMENT**  
AL 6063-T5 .118 THICK




③③ **SASH REINFORCEMENT**  
AL 6063-T5 .118 THICK




③⑥ **RAIL REINFORCEMENT**  
AL 6063-T5 .118 THICK




**SASH CORNER CONSTRUCTION**



**FRAME CORNER CONSTRUCTION**



③⑦ **INSTALLATION STRIP**  
GALVANIZED STEEL G60



③⑧ **FRAME (NAILING FIN)**  
VINYL PVC .069 THICK

PRODUCT REVISED  
as complying with the Florida  
Building Code  
Acceptance No. 13-0805-04  
Expiration Date 02.30.2018  
By *[Signature]*  
Miami Dade Product Control

**KOLBE & KOLBE MILLWORK**  
1211 DEPOT ST  
MANAWA, MI 54949  
  
WINDQUEST V707 SINGLE SLIDER  
74 X 63  
COMPONENTS

DRAWN: R.L.	DWG NO. 08-01323	REV B
SCALE NTS	DATE 08/02/11	SHEET 9 OF 9

SIGNED: 10/11/2013

